

Boil Water Notice Rescinded
February 23, 2021

On **February 15, 2021**, the Texas Commission on Environmental Quality (TCEQ) required the Manville Water Supply Corporation, TX2270033 to issue a Boil Water Notice to inform customers, individuals, or employees that due to conditions which occurred recently in the public water system, the water from this public water system was required to be boiled prior to use for drinking water or human consumption purposes.

The public water system has taken the necessary corrective actions to restore the quality of the water distributed by this public water system used for drinking water or human consumption purposes and has provided TCEQ with laboratory test results that indicate that the water no longer requires boiling prior to use as of **February 23, 2021**.

If you have questions concerning this matter, you may contact our Manville Office at 512-856-2488 or Erik Prinz 512-856-2488 ext. 233.

Due to extreme power surges and loss of power during the recent unprecedented winter storm, the Manville distribution system suffered extensive mechanical equipment failures, causing loss pressure and loss of service to our customers.

Numerous water samples were collected throughout the Manville system and sent to a certified laboratory for bacteriological testing and returned today, confirming water is safe for consumption.

If you wish to contact the TCEQ, please call (512) 239-4691.